

1. **Sender 'Address: -**

The Rising Gurukul School
Village –Bhood,Raipur Rani ,Panchkula.

2. **Source of Water Cooler Sample :-**

W/T At Site (In School)

2. **W/S Collected on Date: -**

27/ March/2021

4. **Received on Date :-**

27.03.2021

5. **Ref. No. : - 194/ 29.03.2021**

6. **Lab. No:-TG/234/03/24**

REPORT ON PHYSICO CHEMICAL ANALYSIS OF WATER

Memo No. 162

Dated. 29-03-2021

Substance/ Characteristic	Result	Desirable Limit	Maximum Permissible Limit (IN absence of of beter alternative source)
		AS per	: IS:10500-2012 Second Revision
Colour ,Hazen Units	Clear	5	15
Odour	Odourless	Un Objectionable	
Turbidity ,NTU	0.39	1	5
Total Dissolved Solids,mg/1	170	500	2000
Total Hardness (Caco3)mg/1	120	200	600
Calcium (Ca3)mg/1	26.0	75	200
Magnesium(Mg)mg/1	28.4	30	100
Total Alkalinity,mg/1	180	200	600
Iron(asFE)mg/1	0.02	0.3	1.0
Chloride (as CL),mg/1	68.1	250	1000
Fluorides (as F)mg/1	0.44	1	1.5
Sulphates (as So4)mg/1	15	200	400
Nitrate (No3)Mg/1	0.6	45	45
PH Value	7.57	6.5—8.5	No relaxn
Bacteriological Exam Coliform/100ml Water Seen	0	0

: OPINION:

The Physico –Chemical Analysis Indicated that above
Water Sample is - **Potable**

Water Sample Collected by sender 'himself' Report is not legal purpose



T & G PURE AQUA PVT. LTD.

Range : STP / ETP, R.O. PLANTS, D.M. PLANTS, WATER COOLER, WATER SOFTNERS
DEEP FREEZER, WATER PURIFIERS (RO/UV), All MS/SS Fabrication Works, (pipelines & Tanks)

waveswater.in

e-mail : wavesindia@hotmail.com

A WATER TREATMENT COMPANY



TO WHOM IT MAY CONCERN

WATER QUALITY REPORT

To.

*The Rising Gurukul School
Village - Bhood,
Raipur Rani - Morni Road
Distt :- Panchkula*

*It is certified that the drinking water quality at
your school is up to the mark.*

*The water is potable & is free from sand, dust,
rust, pathogens & algae. The P.H of the water is also within
considerable limits.*

Dated - 27/03/2021

For T & G Pure Aqua Pvt. Ltd

